



ROC L-16 092461

FIRE EQUIPMENT SALES
AND SERVICE CORPORATION

ROC L-67 092462

3107 W. VIRGINIA AVE. ★ PHX, AZ 85009-1504 ★ (602) 433-2484 ★ Fax (602) 433-9626
2921 S. KISH AVE ★ YUMA, AZ 85386 ★ (928) 341-0026 ★ Fax (928) 341-0356
SHOW LOW ★ PINETOP ★ LAKESIDE ★ (928) 532-2292

September 16, 2012

J.B. Akins
Blue Ridge Unified School District #32
1200 W. White Mountain Blvd
Lakeside, AZ 85929

Phone: 928-368-8266 Ext 120
Fax: 928-368-4008
Cell: 928-205-9843
Email: jakins@brusd.k12.az.us

RE: SLM182 Elementary School Fire Pump House

American Fire Equipment would like to present you with the following proposal for the above referenced facility.

*** Deficiencies Noted:**

- Jockey pump does not function.
- The suction pressure gauge needs to be replaced.
- Fuel tank is half full and is required to at least be 2/3 full.
- Motor would not start on battery #2.
- Fire sprinkler heads do not meet the requirements of "Extra Hazard" (Group 2).
- Fire pump does not start on pressure drop, had to test by manually starting pump.

Scope of Work:

- Provide a complete fire pump service, which will include repairing all of the above and retesting fire pump. Due to lack of service on pump, this will be billed on a time and material bases.

T & M Not to exceed \$ 1,740.00 without prior approval.